

2021 REPORT WATER QUALITY



This is your annual water quality report for the period of January 1 through December 31, 2021. Each year the Village issues this report to provide you information about the quality of our drinking water, the source of our water, how it is treated, and the regulated compounds it contains. These reports are issued in compliance with the Safe Drinking Water Act. For more detailed information about our water's quality, including test results for unregulated compounds, contact Melissa Olenick at CLCJAWA at 847-295-7788 or email at molenick@clcjawa.com, Brett Fritzler at 847-599-6800, visit our web page at www.gurnee.il.us, or visit the CLCJAWA web page at www.clcjawa.com.

Este informe contiene información muy importante sobre el agua que usted bebe. Tradúzcalo ó hable con alguien que lo entienda bien. Some people may be more vulnerable to contaminants in drinking water than the general population. Immuno-compromised persons such as persons with cancer undergoing chemotherapy, persons who have undergone organ transplants, people with HIV/AIDS or other immune system disorders, some elderly, and infants can be particularly at risk from infections. These people should seek advice about drinking water from their health care providers. USEPA/CDC guidelines on appropriate means to lessen the risk of infection by *Cryptosporidium* and other microbial contaminants are available from the USEPA's Safe Drinking Water Hotline (1-800-426-4791).



The Village of
Gurnee & CLCJAWA
were in full
compliance with all
State & Federal
Regulations in 2021

EXCELLENCE IN DRINKING WATER

CLCJAWA has received the Excellence in Water Treatment award for the last 17 years and was the third facility in the nation to achieve this distinction presented by the Partnership for Safe Water. This voluntary water quality program, sponsored in part by the United States Environmental Protection Agency, holds its awardees to higher standards than required by current Federal and State drinking water regulations.

This year CLCJAWA was 5th in the nation to be honored with the Partnership for Safe Water Distribution System Presidents Award. This is a significant achievement towards ensuring the delivery of safe, high-quality water to the community.



VILLAGE OF GURNEE - 325 O'PLAINE ROAD - GURNEE, IL
WWW.GURNEE.IL.US - 847-599-7500

WATER CONTAMINANTS DETECTED IN 2021

Definition of Terms:

Units of Measure:

ppm: parts per million or milligrams per liter

ppb: parts per billion or micrograms per liter

pCi/L: picocuries per liter used to measure radioactivity

NTU: nephelometric turbidity unit that measures clarity in drinking

Action Level (AL): The concentration of a contaminant that triggers treatment or other required actions by the water supply.

Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.

Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.

Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.

Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.

Maximum Residual Disinfectant Level (MRDL): The highest level of a drinking water disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Water Quality Contaminants Detected in 2021

Contaminant (unit of measure) Typical Source of Contaminant	Highest Level Detected	MCLG	MCL	Range of Detection	Violation	Date of Sample
MICROBIAL CONTAMINANTS						
Total Coliform Bacteria (% Pos/Month) Naturally present; human and animal fecal waste	1	0	1 per month	-----	In Compliance	09/14/2021 Monthly
E. Coli (% Pos/Month) Naturally present; human and animal fecal waste	0	0	0 per month	-----	In Compliance	Monthly
Turbidity ¹(NTU/Lowest Monthly % < 0.3 NTU) Lake Sediment; soil runoff	100% below 0.3 NTU	none	0.3 NTU	100%	In Compliance	Monthly
Turbidity ¹(NTU/Highest Single Measurement) Lake Sediment; soil runoff	0.051	none	1 NTU	0.02 – 0.051	In Compliance	Monthly
INORGANIC CONTAMINANTS						
Nitrate as nitrogen (ppm) Runoff from fertilizer; leaching from septic; natural erosion	0.3	10	10	Single Sample	In Compliance	08/26/2021
Barium (ppm) Discharge of drilling wastes & metal refineries; natural erosion	0.023	2	2	Single Sample	In Compliance	08/04/2021
Copper ²(ppm) Corrosion of household plumbing systems; natural erosion	0.16 90 th Percentile	1.3	AL = 1.3	0 Sites over AL	In Compliance	08/2021
Lead ²(ppb) Corrosion of household plumbing systems; natural erosion	1.3 90 th Percentile	0	AL = 15	0 Sites over AL	In Compliance	08/2021
DISINFECTANT/DISINFECTION BY-PRODUCTS						
HAA5 Haloacetic Acids (ppb) By-product of drinking water disinfection	8	none	60	3.78 – 12.76	In Compliance	Quarterly
TTHMs Total Trihalomethanes (ppb) By-product of drinking water disinfection	18	none	80	9.11 – 28	In Compliance	Quarterly
Bromate (ppb) By-product of drinking water disinfection	1	0	10	0 – 3.3	In Compliance	07/13/2021 Quarterly
Chlorine (ppm) Drinking water disinfectant	0.9	4	4	0.7 – 1	In Compliance	Daily
TOC (Total Organic Carbon)	The % of TOC removal was measured each month & the system met all removal requirements set by IEPA					

The table above lists all of the regulated compounds detected in our water. Bolded compounds were sampled by the Village; all other compounds were sampled by CLCJAWA. The values shown in the level detected column are those used by the EPA to determine compliance with drinking water standards. Because each compound is regulated differently, this value may be a running average, a 90th percentile or a maximum single value. The sample data column indicates the date when the sample was collected. When more than one sample is collected, this column shows the date of the maximum value.

- 1) Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.
- 2) The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, is more than one year old.
- 3) A maximum contaminant level (MCL) for this contaminant has not been established by either state or federal regulations, nor has mandatory health effects language been set. The purpose of unregulated contaminant monitoring is to assist USEPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.
- 4) These contaminants are not currently regulated by the USEPA. However, the state has set an MCL for these contaminants for supplies serving a population of 1,000 or more.
- 5) A maximum contaminant level (MCL) for this contaminant has not been established by either state or federal regulations, nor has mandatory health effects language been set. The purpose of unregulated contaminant monitoring is to assist USEPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Units of Measure:	Definition of Terms:
ppm: parts per million or milligrams per liter	Action Level (AL): The concentration of a contaminant that triggers treatment or other required actions by the water supply.
ppb: parts per billion or micrograms per liter	Maximum Contaminant Level (MCL): The highest level of a contaminant that is allowed in drinking water. MCLs are set as close to the MCLGs as feasible using the best available treatment technology.
pCi/L: picocuries per liter used to measure radioactivity	Maximum Contaminant Level Goal (MCLG): The level of a contaminant in drinking water below which there is no known or expected risk to health. MCLGs allow for a margin of safety.
NTU: nephelometric turbidity unit that measures clarity in drinking	Treatment Technique (TT): A required process intended to reduce the level of a contaminant in drinking water.
	Maximum Residual Disinfectant Level Goal (MRDLG): The level of a drinking water disinfectant below which there is no known or expected risk to health. MRDLGs do not reflect the benefits of the use of disinfectants to control microbial contaminants.
	Maximum Residual Disinfectant Level (MRDL): The highest level of a drinking water disinfectant allowed in drinking water. There is convincing evidence that addition of a disinfectant is necessary for control of microbial contaminants.

Water Quality Contaminants Detected in 2021

Contaminant (unit of measure) Typical Source of Contaminant	Highest Level Detected	MCLG	MCL	Range of Detection	Violation	Date of Sample
UNREGULATED CONTAMINANTS^{2, 5}						
Asbestos³ (MFL) Natural mineral from rocks and soil	<0.20	none	none	Single Sample	In Compliance	12/01/2020
Manganese³ (ppm) Natural mineral from rocks and soil	0.0031	None	0.05	Single Sample	In Compliance	3/7/2019
STATE REGULATED CONTAMINANTS⁵						
Fluoride (ppm) Water additive which promotes strong teeth; natural erosion	0.7	4	4	0.6 – 0.7	In Compliance	01/07/2021 Monthly
Sodium (ppm) Erosion of naturally occurring deposits; water softener	9.7	none	none	Single Sample	In Compliance	08/04/2021
RADIOACTIVE CONTAMINANTS						
Combined Radium 226/228²(pCi/L) Decay of natural and man-made deposits	20.49	0	5	Single Sample	In Compliance	02/22/2021
Gross Alpha Emitters²(pCi/L) Erosion of natural deposits	66.2	0	15	Single Sample	In Compliance	02/22/2021

The table above lists all of the regulated compounds detected in our water. Bolded compounds were sampled by the Village; all other compounds were sampled by CLCJAWA. The values shown in the level detected column are those used by the EPA to determine compliance with drinking water standards. Because each compound is regulated differently, this value may be a running average, a 90th percentile or a maximum single value. The sample data column indicates the date when the sample was collected. When more than one sample is collected, this column shows the date of the maximum value.

- 1) Turbidity is a measurement of the cloudiness of the water caused by suspended particles. We monitor it because it is a good indicator of water quality and the effectiveness of our filtration system and disinfectants.
- 2) The state requires us to monitor for certain contaminants less than once per year because the concentrations of these contaminants do not change frequently. Some of our data, though accurate, is more than one year old.
- 3) A maximum contaminant level (MCL) for this contaminant has not been established by either state or federal regulations, nor has mandatory health effects language been set. The purpose of unregulated contaminant monitoring is to assist USEPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.
- 4) These contaminants are not currently regulated by the USEPA. However, the state has set an MCL for these contaminants for supplies serving a population of 1,000 or more.
- 5) A maximum contaminant level (MCL) for this contaminant has not been established by either state or federal regulations, nor has mandatory health effects language been set. The purpose of unregulated contaminant monitoring is to assist USEPA in determining the occurrence of unregulated contaminants in drinking water and whether future regulation is warranted.

Drinking water, including bottled water, may reasonably be expected to contain at least small amounts of some contaminants. The presence of contaminants does not necessarily indicate that water poses a health risk. More information about contaminants and potential health effects can be obtained by calling the USEPA's Safe Drinking Water Hotline (1-800-426-4791). Both tap and bottled water come from rivers, lakes, streams, ponds, reservoirs, springs, and wells. As water travels over the surface of land or through the ground, it dissolves naturally occurring materials and can pick up substances resulting from the presence of animal or human activity. Contaminants that may be present in untreated water include:

- Microbial contaminants such as viruses and bacteria can be naturally occurring or may come from sewage treatment plants, septic systems, and livestock operations.
- Inorganic contaminants such as salts and metals can be naturally occurring or result from urban storm water runoff, wastewater discharges, oil and gas production, mining, or farming.
- Pesticides and herbicides come from sources such as agricultural, urban and residential storm water runoff.
- Organic chemical contaminants including synthetic and volatile organic compounds are by-products of industrial processes and petroleum production but can also come from gas stations, urban storm water runoff and septic system.
- Radioactive contaminants can be naturally occurring or be the result of oil, gas and mining activities. Pesticides and herbicides come from sources such as agricultural and residential storm water runoff.



If present, elevated levels of lead can cause serious health problems, especially for pregnant women and young children. Some homes with old lead service lines, lead plumbing, or copper plumbing with lead solder, may have lead and copper in their water. To minimize these levels, the Illinois EPA requires that CLCJAWA add phosphate to our water at a concentration of 0.3 ppm orthophosphate. This commonly used food ingredient thinly coats the inside of your premise plumbing.


Lead in drinking water is primarily from materials and components associated with service lines and home plumbing. The Village of Gurnee is responsible for providing high quality drinking water, but cannot control the variety of materials used in plumbing components. When your water has been sitting for several hours, you can minimize the potential for lead and copper exposure by flushing your tap for 30 seconds to 2 minutes before using water for cooking or drinking. If you are concerned about lead in your water, you may wish to have your water tested.

Water providers are now generating an inventory of all known lead service lines in use, and are issuing public notification to homeowners of local water main construction or repair work that might increase the risk of lead exposure. For more information on lead in drinking water, testing methods and steps you can take to minimize exposure, contact the Safe Drinking Water Hotline at 1-800-426-4791 or go to <http://www.epa.gov/safewater/lead>.

OUR SOURCE WATER

The Illinois EPA, using the Great Lakes Protocol, completed source water assessment in April 2003. Lake Michigan is a surface water source and like all surface waters, is susceptible to potential contaminants. The very nature of surface water allows contaminants to migrate to the intake with no protection, only dilution. CLCJAWA's intake is ranked as moderately sensitive to potential contaminants. There are no potential contamination sources within the intake's critical assessment zone. However, the combination of land use, storm sewer outfalls, and the proximity of North Shore Water Reclamation District (NSWRD) pumping stations in the immediate area add to the susceptibility of CLCJAWA's intake. NSWRD discharges their treated waste water to the Des Plaines River and not into Lake Michigan. Access the following website at <http://www.epa.state.il.us/cgi-bin/wp/swap-fact-sheets.pl> to view a summary of the source water assessment. We are all participants in the water cycle. Our individual activities impact the rivers and lakes in our watershed and those into which our waste water plants discharge. Please properly use, store, and dispose of all medications and household chemicals. Visit the Solid Waste Agency of Lake County website for disposal options and information at www.swalco.org.

Our water is pumped from Lake Michigan and treated at CLCJAWA's Paul M. Neal Water Treatment Facility in the Village of Lake Bluff. The enhanced water purification process used by CLCJAWA is unique. First, the water is treated with ozone to kill organisms and break down contaminants. Ozone is produced on-site from air, bubbled into the water, and then converted back into oxygen. The water is then mixed with coagulant to remove sediment and other material from the water. Once clarified, the water is further refined as it passes through filters containing activated carbon and fine sand to remove any remaining cloudiness or turbidity. Turbidity is then measured to determine water clarity. Treatment facilities monitor turbidity because it is a good indicator of water quality and the effectiveness of their filtration and disinfection systems. At CLCJAWA, turbidity is checked every ten seconds in numerous locations by automatic monitoring equipment and twice a day, by hand, in the laboratory (see results on page 2). Next the water is treated with ultraviolet light to inactivate any remaining organisms. Finally, the purified water is treated with chlorine to protect it as it travels through the water main, fluoride for dental health, and a small amount of an often-used food additive called phosphate. Phosphate protects the water from metals, such as lead and copper, found in our homes' plumbing systems.



Villages purchase water from the Central Lake County Joint Action Water Agency. CLCJAWA is an inter-governmental cooperative, directed by the communities it serves: Grayslake, Gurnee, Lake Bluff, Lake Villa, Libertyville, Lindenhurst, Mundelein, Round Lake, Round Lake Beach, Round Lake Heights, Round Lake Park, Volo, Wauconda and Lake County representing the unincorporated areas of Knollwood and Rondout, Vernon Hills, Wildwood, Grandwood Park and Fox Lake Hills.

CLCJAWA utilizes over 50 miles of pre-stressed concrete, ductile iron and PVC water main to deliver water to your community. Your public works department, in turn, maintains its own water distribution system that delivers the water to homes, schools and businesses in the community.

The Village services over 9,800 water accounts and is responsible for maintaining over 190 miles of water main. Water is stored in 4 elevated tanks and one ground storage tank for a total storage capacity of 8 million gallons. In addition to CLCJAWA, the Village also maintains two emergency back-up wells. These two wells are routinely tested in accordance with IEPA regulations. The Village also maintains a connection with the City of Waukegan as an additional back-up source.

The source water assessment for our supply has been completed by the Illinois EPA. If you would like a copy of this information, or information regarding the back-up wells, please contact Public Works at 847-599-6800. Information provided by this assessment did not indicate any potential sources of contamination.

DRINKING WATER REGULATORY AGENCIES

In order to ensure that tap water is safe to drink, USEPA prescribes regulations that limit the amount of certain contaminants in water provided by public water systems. FDA regulations establish limits for contaminants in bottled water, which must provide the same protection for public health. Water quality may be judged by comparing our water to USEPA benchmarks for water quality. One such benchmark is the Maximum Contaminant Level Goal (MCLG). The MCLG is the level of a contaminant in drinking water below which there is no known or expected risk to health. This goal allows for a margin of safety. Another benchmark is the Maximum Contaminant Level (MCL). An MCL is the highest level of a contaminant that is allowed in drinking water. An MCL is set as close to an MCLG as feasible using the best available treatment technology.

Our tap water quality is consistently monitored by the Village, by the Illinois Environmental Protection Agency (IEPA), in the CLCJAWA Water Quality Lab, and by other independent labs. This aggressive water quality assurance program is thorough: bacteriological tests are conducted six times more often than required, water clarity is monitored every 10 seconds, and our water is checked for over three hundred contaminants annually. The Village Board has a monthly meeting schedule, and the public is always welcome to attend any of these meetings. Your Mayor is also a member of the Board of Directors of CLCJAWA, which meets regularly. Please visit the website at www.clcjawa.com for the current meeting schedule. CLCJAWA provides tours of the water treatment facility, and staff members are also available for public speaking or for school visits. Please contact the Village or CLCJAWA for more information.